

# 

This checklist is designed to give businesses a quick appraisal of potential problem areas for accessibility. For detailed review standards contact the Architectural and Transportation Barriers Compliance Board at 1/800/872-2253 and/or obtain a copy of the Uniform Federal Accessibility Standards for current specifications.

ITEM TO BE PERFORMED	YES	NO
<b>Building Access</b>		
1. Are 96" wide parking spaces designated with a 60" access aisle?	<input type="checkbox"/>	<input type="checkbox"/>
2. Are parking spaces near main building entrance?	<input type="checkbox"/>	<input type="checkbox"/>
3. Is there a drop off zone at building entrance?	<input type="checkbox"/>	<input type="checkbox"/>
4. Is the gradient from parking to building entrance 1:12 or less?	<input type="checkbox"/>	<input type="checkbox"/>
5. Is the entrance doorway at least 32 inches?	<input type="checkbox"/>	<input type="checkbox"/>
6. Is door handle easy to grasp?	<input type="checkbox"/>	<input type="checkbox"/>
7. Is door easy to open (less than 8 lbs. pressure)?	<input type="checkbox"/>	<input type="checkbox"/>
8. Are other than revolving doors available?	<input type="checkbox"/>	<input type="checkbox"/>
<b>Building Corridors</b>		
1. Is path of travel free of obstruction and wide enough for a wheelchair?	<input type="checkbox"/>	<input type="checkbox"/>
2. Is floor surface hard and not slippery?	<input type="checkbox"/>	<input type="checkbox"/>
3. Do obstacles (phones, fountains) protrude no more than four inches?	<input type="checkbox"/>	<input type="checkbox"/>
4. Are elevator controls low enough (48") to be reached from a wheelchair?	<input type="checkbox"/>	<input type="checkbox"/>
5. Are elevator markings in Braille for the blind?	<input type="checkbox"/>	<input type="checkbox"/>
6. Does elevator provide audible signals for the blind?	<input type="checkbox"/>	<input type="checkbox"/>
7. Does elevator interior provide a turning area of 51" for wheelchairs?	<input type="checkbox"/>	<input type="checkbox"/>
<b>Restrooms</b>		
1. Are restrooms near building entrance/personnel office?	<input type="checkbox"/>	<input type="checkbox"/>
2. Do doors have lever handles?	<input type="checkbox"/>	<input type="checkbox"/>
3. Are doors at least 32" wide?	<input type="checkbox"/>	<input type="checkbox"/>
4. Is restroom large enough for wheelchair turnaround (51" minimum)?	<input type="checkbox"/>	<input type="checkbox"/>
5. Are stall doors at least 32" wide?	<input type="checkbox"/>	<input type="checkbox"/>
6. Are grab bars provided in toilet stalls?	<input type="checkbox"/>	<input type="checkbox"/>
7. Are sinks at least 30" high with room for a wheelchair to roll under?	<input type="checkbox"/>	<input type="checkbox"/>
8. Are sink handles easily reached and used?	<input type="checkbox"/>	<input type="checkbox"/>
9. Are soap dispensers, towels, no more than 48" from floor?	<input type="checkbox"/>	<input type="checkbox"/>
<b>Personnel Office</b>		
1. Are doors at least 32" wide?	<input type="checkbox"/>	<input type="checkbox"/>
2. Is the door easy to open?	<input type="checkbox"/>	<input type="checkbox"/>
3. Is the threshold no more than 1/2" high?	<input type="checkbox"/>	<input type="checkbox"/>
4. Is the path of travel between desks, tables wide enough for wheelchairs?	<input type="checkbox"/>	<input type="checkbox"/>